

# Test Report

Report No 255/4941766 This Report consists of 11 pages

Licence/Cert. No CE 70730

Client Handan Hengyong Protective and Clean Products Company Limited  
300 Gongnong Road  
Shijiazhuang Hebei  
Republic of China  
050051

Authority & date BSI Product Service: Service Management Order No 4941766  
Dated 11 January 2007. Equipment Record No 10083262

Items tested Model: Thirty (30) off Handan Hengyong HY9320 FFP1/2 Foldable Masks

Specification Limited testing to BS EN 149:2001 Respiratory protective devices –  
Filtering half masks to protect against particles

Results See Assessment Summary

Prepared by J Veasey Test Engineer  
A Harding Test Engineer

Authorized by D Mackie Senior Engineer

Issue Date 22 January 2007

Conditions of issue



This Test Report is issued subject to the conditions stated in current issue of PS082 'General conditions relating to acceptance of testing'. The results contained herein apply only to the particular sample/s tested and to the specific tests carried out, as detailed in this Test Report. The issuing of this Test Report does not indicate any measure of Approval, Certification, Supervision, Control or Surveillance by BSI of any product. No extract, abridgement or abstraction from a Test Report may be published or used to advertise a product without the written consent of the Managing Director, BSI Product Services, who reserves the absolute right to agree or reject all or any of the details of any items or publicity for which consent may be sought.



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**

**SPECIFICATION:-** Limited testing to BS EN 149:2001 Respiratory protective devices -  
Filtering half masks to protect against particles  
(see Assessment Summary for details)

**CLIENT/MANUFACTURER:** Handan Hengyong Protective and Clean Products Company Limited

**MODEL:** HY9320 FFP1/2 Foldable Masks

**NUMBER OF SAMPLES & SIZES:** 15 tested of 30 submitted for test

**ER NO:**10083262

**DATE RECEIVED:** 11 January 2006

**DATE STARTED:** 11 January 2006

**MANUFACTURER'S CLAIMED EQUIPMENT PERFORMANCE:-**

Filter classification: FFP1/2

**INTRODUCTION**

The samples detailed above were submitted by the Client for a limited test programme.

This Report should be read in conjunction with the Specifications referenced above

Unless specified all testing was performed in accordance with EN 149:2001

**ASSESSMENT SUMMARY**

An Assessment Summary is presented on page 3.



BSI PRODUCT SERVICES  
BS EN 149:2001

ASSESSMENT SUMMARY

CLAUSE NO AND TITLE		ASSESSMENT	LOCATION
7	REQUIREMENTS		
7.1	General	Pass(4)	Page 4
7.2	Nominal values and tolerances	-	Page 4
7.3	Visual inspection	N/As (1)	-
7.4	Packaging	N/As (1)	-
7.5	Material	N/As (1)	-
7.6	Cleaning and disinfecting	N/As (1)	-
7.7	Practical performance	N/As (1)	-
7.8	Finish of parts	Pass	Page 5
7.9	Leakage		
7.9.1	Total inward leakage	N/As (1)	-
7.9.2	Penetration of filter material	Pass	Pages 6 & 7
7.10	Compatibility with skin	N/As (1)	-
7.11	Flammability	N/As (1)	-
7.12	Carbon dioxide content of inhalation air		Page 8
7.13	Head harness	N/As (1)	-
7.14	Field of vision	N/As (1)	-
7.15	Exhalation valve(s)	N/As (1)	-
7.16	Breathing resistance	Pass	Pages 9 to 11
7.17	Clogging	N/As (3)	-
7.18	Demountable parts	N/As (2)	-
9	Marking	N/As (1)	-
10	Information to be supplied by the manufacturer	N/As (1)	-

N/As: Not Assessed

- N/As: Not Assessed
- N/As: Not Assessed
- (1) Not required by BSI Product Certification.
- (2) Not applicable to this product.
- (3) Option not claimed
- (4) All requirements requested by Product Certification Passed



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**

**EXAMINATION AND TEST (CONTINUED)**

**Model Type :- HY9320 FFP1/2 Foldable Masks**

CLAUSE	REQUIREMENT	ASSESSMENT
<b>7</b>	<b>REQUIREMENTS</b>	
<b>7.1</b>	<b>General</b> In all tests all samples shall meet the requirements.	Pass (2)
<b>7.2</b>	<b>Nominal values and tolerances</b> Unless otherwise specified, the values stated in this European Standard are expressed as nominal values. Except for temperature limits, values, which are not stated as maxima or minima, shall be subject to a tolerance of $\pm 5\%$ . Unless otherwise specified, the ambient temperature for testing shall be $(16 - 32) ^\circ\text{C}$ , and the temperature limits shall be subject to an accuracy of $\pm 1^\circ\text{C}$ .	-
<b>7.3</b>	<b>Visual Inspection</b> The visual inspection shall also include the marking and the information supplied by the manufacturer.	N/As (1)
<b>7.4</b>	<b>Packaging</b> Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use. Test in accordance with clause 8.2 of the standard.	N/As (1)
<b>7.5</b>	<b>Material</b> Materials used are suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used. After undergoing the conditioning described in clause 8.3.1 of the standard none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps. When conditioned in accordance with clauses 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse. Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer. Test in accordance with clause 8.2 of the standard.	N/As (1) N/As (1) N/As (1) N/As (1)

N/As: Not Applicable

N/As: Not Assessed

(1) Not required by BSI Product Certification.

(2) All requirements requested by Product Certification Passed



BSI PRODUCT SERVICES  
BS EN 149:2001

EXAMINATION AND TEST (CONTINUED)

Model Type :- HY9320 FFP1/2 Foldable Masks

CLAUSE	REQUIREMENT	ASSESSMENT
7.6	<b>Cleaning and disinfecting</b> If the particle filtering half mask is designed for more than a single shift (i.e. not designed for single use only) the materials used shall withstand the cleaning and disinfecting agents recommended by the manufacturer. Test in accordance with clauses 8.4 and 8.5 of the standard.	N/Ap (2)
7.7	<b>Practical performance</b> The particle filtering half mask shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the equipment for imperfections that cannot be determined by the tests described elsewhere in this standard.  Where practical performance tests show the apparatus has imperfections related to wearer's acceptance, the test house shall provide full details of those parts of the practical performance tests which revealed these imperfections. Test in accordance with clause 8.4 of the standard.	N/As (1)
7.8	<b>Finish of parts</b> Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs. Test in accordance with clause 8.2 of the standard.	Pass

N/Ap: Not Applicable                      N/As: Not Assessed

- (1) Not required by BSI Product Certification.
- (2) Not applicable to this product.



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**  
**EXAMINATION AND TEST (CONTINUED)**

**Model Type :- HY9320 FFP1/2 Foldable Masks**

CLAUSE	REQUIREMENT	ASSESSMENT																																																																	
7.9 7.9.2	<p><b>Leakage (continued)</b></p> <p>Penetration of filter material (Continued next page)</p> <p>The penetration of the filter of the particle filtering half mask shall meet the requirements of Table 1 of the standard. A total of 12 particle filtering half masks shall be tested for each aerosol: 3 as received, 3 after temperature conditioning in accordance with clause 8.3.2, 3 after the simulated wearing treatment described in clause 8.3.1, and 3 after the test for mechanical strength in accordance with clause 8.3.3. Test in accordance with clause 8.11 of the standard.</p> <p>Table B. Maximum sodium chloride penetration @ 95 l/min</p> <table><tr><th>Sample No</th><th>Pre-test condition</th><th>Flow through filter (l/min)</th><th>Max Specified Penetration (%)</th><th>Actual Penetration (%)</th></tr><tr><td>1</td><td>AR</td><td>95</td><td>6.0</td><td>0.6289</td></tr><tr><td>2</td><td>AR</td><td>95</td><td>6.0</td><td>0.0949</td></tr><tr><td>3</td><td>AR</td><td>95</td><td>6.0</td><td>0.2545</td></tr><tr><td>4</td><td>TC</td><td>95</td><td>6.0</td><td>0.3933</td></tr><tr><td>5</td><td>TC</td><td>95</td><td>6.0</td><td>0.5713</td></tr><tr><td>6</td><td>TC</td><td>95</td><td>6.0</td><td>0.0985</td></tr><tr><td>7</td><td>SW</td><td>95</td><td>6.0</td><td>0.0390</td></tr><tr><td>8</td><td>SW</td><td>95</td><td>6.0</td><td>0.2666</td></tr><tr><td>9</td><td>SW</td><td>95</td><td>6.0</td><td>0.0205</td></tr><tr><td>10</td><td>MS</td><td>95</td><td>6.0</td><td>0.3263</td></tr><tr><td>11</td><td>MS</td><td>95</td><td>6.0</td><td>0.7162</td></tr><tr><td>12</td><td>MS</td><td>95</td><td>6.0</td><td>0.6491</td></tr></table>	Sample No	Pre-test condition	Flow through filter (l/min)	Max Specified Penetration (%)	Actual Penetration (%)	1	AR	95	6.0	0.6289	2	AR	95	6.0	0.0949	3	AR	95	6.0	0.2545	4	TC	95	6.0	0.3933	5	TC	95	6.0	0.5713	6	TC	95	6.0	0.0985	7	SW	95	6.0	0.0390	8	SW	95	6.0	0.2666	9	SW	95	6.0	0.0205	10	MS	95	6.0	0.3263	11	MS	95	6.0	0.7162	12	MS	95	6.0	0.6491	See Table B
Sample No	Pre-test condition	Flow through filter (l/min)	Max Specified Penetration (%)	Actual Penetration (%)																																																															
1	AR	95	6.0	0.6289																																																															
2	AR	95	6.0	0.0949																																																															
3	AR	95	6.0	0.2545																																																															
4	TC	95	6.0	0.3933																																																															
5	TC	95	6.0	0.5713																																																															
6	TC	95	6.0	0.0985																																																															
7	SW	95	6.0	0.0390																																																															
8	SW	95	6.0	0.2666																																																															
9	SW	95	6.0	0.0205																																																															
10	MS	95	6.0	0.3263																																																															
11	MS	95	6.0	0.7162																																																															
12	MS	95	6.0	0.6491																																																															

AR: As Received  
 SW: Simulated Wear

TC: Temperature Conditioned  
 MS: Mechanical strength



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**  
**EXAMINATION AND TEST (CONTINUED)**

**Model Type :- HY9320 FFP1/2 Foldable Masks**

CLAUSE	REQUIREMENT	ASSESSMENT																																																																	
7.9	<b>Leakage (continued)</b>	See Table C																																																																	
7.9.2	Penetration of filter material (Continued)																																																																		
	The penetration of the filter of the particle filtering half mask shall meet the requirements of Table 1 of the standard. A total of 12 particle filtering half masks shall be tested for each aerosol: 3 as received, 3 after temperature conditioning in accordance with clause 8.3.2, 3 after the simulated wearing treatment described in clause 8.3.1, and 3 after the test for mechanical strength in accordance with clause 8.3.3. Test in accordance with clause 8.11 of the standard.																																																																		
	Table C. Maximum paraffin oil penetration @ 95 l/min																																																																		
	<table><tr><th>Sample No</th><th>Pre-test condition</th><th>Flow through filter (l/min)</th><th>Max Specified Penetration (%)</th><th>Actual Penetration (%)</th></tr><tr><td>1</td><td>AR</td><td>95</td><td>6.0</td><td>0.25</td></tr><tr><td>2</td><td>AR</td><td>95</td><td>6.0</td><td>0.20</td></tr><tr><td>3</td><td>AR</td><td>95</td><td>6.0</td><td>0.26</td></tr><tr><td>4</td><td>TC</td><td>95</td><td>6.0</td><td>0.60</td></tr><tr><td>5</td><td>TC</td><td>95</td><td>6.0</td><td>0.55</td></tr><tr><td>6</td><td>TC</td><td>95</td><td>6.0</td><td>0.23</td></tr><tr><td>7</td><td>SW</td><td>95</td><td>6.0</td><td>0.15</td></tr><tr><td>8</td><td>SW</td><td>95</td><td>6.0</td><td>0.50</td></tr><tr><td>9</td><td>SW</td><td>95</td><td>6.0</td><td>0.11</td></tr><tr><td>10</td><td>MS</td><td>95</td><td>6.0</td><td>0.40</td></tr><tr><td>11</td><td>MS</td><td>95</td><td>6.0</td><td>0.70</td></tr><tr><td>12</td><td>MS</td><td>95</td><td>6.0</td><td>0.80</td></tr></table>		Sample No	Pre-test condition	Flow through filter (l/min)	Max Specified Penetration (%)	Actual Penetration (%)	1	AR	95	6.0	0.25	2	AR	95	6.0	0.20	3	AR	95	6.0	0.26	4	TC	95	6.0	0.60	5	TC	95	6.0	0.55	6	TC	95	6.0	0.23	7	SW	95	6.0	0.15	8	SW	95	6.0	0.50	9	SW	95	6.0	0.11	10	MS	95	6.0	0.40	11	MS	95	6.0	0.70	12	MS	95	6.0	0.80
Sample No	Pre-test condition		Flow through filter (l/min)	Max Specified Penetration (%)	Actual Penetration (%)																																																														
1	AR		95	6.0	0.25																																																														
2	AR		95	6.0	0.20																																																														
3	AR		95	6.0	0.26																																																														
4	TC		95	6.0	0.60																																																														
5	TC		95	6.0	0.55																																																														
6	TC		95	6.0	0.23																																																														
7	SW	95	6.0	0.15																																																															
8	SW	95	6.0	0.50																																																															
9	SW	95	6.0	0.11																																																															
10	MS	95	6.0	0.40																																																															
11	MS	95	6.0	0.70																																																															
12	MS	95	6.0	0.80																																																															
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	
		Pass																																																																	

AR: As Received  
 SW: Simulated Wear

TC: Temperature Conditioned  
 MS: Mechanical strength



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**  
**EXAMINATION AND TEST (CONTINUED)**

**Model Type :- HY9320 FFP1/2 Foldable Masks**

CLAUSE	REQUIREMENT	ASSESSMENT																
7.11	<b>Flammability</b>	N/As (1)																
7.12	<b>Carbon dioxide content of inhalation air</b> The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1.0% (by volume). Test in accordance with clause 8.7 of the standard.  Table D: Carbon dioxide content of the inhalation air <table><tr><th>Sample No</th><th>Pre-test condition</th><th>Maximum Specified CO<sub>2</sub> (%)</th><th>Actual CO<sub>2</sub> (%)</th></tr><tr><td>13</td><td>AR</td><td>1.0</td><td>0.74</td></tr><tr><td>14</td><td>AR</td><td>1.0</td><td>0.85</td></tr><tr><td>15</td><td>AR</td><td>1.0</td><td>0.76</td></tr></table>	Sample No	Pre-test condition	Maximum Specified CO <sub>2</sub> (%)	Actual CO <sub>2</sub> (%)	13	AR	1.0	0.74	14	AR	1.0	0.85	15	AR	1.0	0.76	See Table D
Sample No	Pre-test condition	Maximum Specified CO <sub>2</sub> (%)	Actual CO <sub>2</sub> (%)															
13	AR	1.0	0.74															
14	AR	1.0	0.85															
15	AR	1.0	0.76															
	A total of 9 valveless filtering half masks shall be tested: 3 as received, 3 after temperature conditioning in accordance with clause 8.3.2, and 3 after the test for simulated wearing in accordance with clause 8.3.1. Test in accordance with clause 8.9 of the standard.  A total of 12 valved particle filtering half masks shall be tested: 3 as received, 3 after temperature conditioning in accordance with clause 8.3.2, 3 after the test for simulated wearing in accordance with clause 8.3.1, and 3 after the flow conditioning in accordance with clause 8.3.4. Test in accordance with clause 8.9 of the standard.	See Tables E, F and G  See Tables E, F and G																
7.13	<b>Head harness</b> The head harness shall be designed so that the particle filtering half mask can be donned and removed easily. The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and be capable of maintaining total inward leakage requirements for the device. Test in accordance with clauses 8.4 and 8.5 of the standard.	N/Ap (1)																

N/Ap: Not Applicable

N/As: Not Assessed

(1) Not required by BSI Product Certification.

(2) Not applicable to this product.

**EXAMINATION AND TEST (CONTINUED)**



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**  
**EXAMINATION AND TEST (CONTINUED)**

**Model Type :- HY9320 FFP1/2 Foldable Masks**

CLAUSE	REQUIREMENT	ASSESSMENT
7.14	<b>Field of vision</b> The field of vision is acceptable if determined so in practical performance tests. Test in accordance with clause 8.4.	N/Ap (1)
7.15	<b>Exhalation valves</b> A particle filtering half mask may have one or more exhalation valve(s), which shall function correctly in all orientations. Test in accordance with clauses 8.2 and 8.9.1 If an exhalation valve is provided it shall be protected against, or be resistant to, dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9. Test in accordance with clause 8.2 of the standard. Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30 s. Test in accordance with clause 8.3.4. When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 10 N applied for 10 seconds. Test in accordance with clause 8.8.	N/Ap (1)
7.16	<b>Breathing resistance</b> The breathing resistances apply to valved and valveless particle filtering half masks and shall meet the requirements of Table 2 of the standard. A total of 9 valveless filtering half masks shall be tested: 3 as received, 3 after temperature conditioning in accordance with clause 8.3.2, and 3 after the test for simulated wearing in accordance with clause 8.3.1. Test in accordance with clause 8.9 of the standard. A total of 12 valved particle filtering half masks shall be tested: 3 as received, 3 after temperature conditioning in accordance with clause 8.3.2, 3 after the test for simulated wearing in accordance with clause 8.3.1, and 3 after the flow conditioning in accordance with clause 8.3.4. Test in accordance with clause 8.9 of the standard.	(See Tables E, F and G)  (See Tables E, F and G)

N/Ap: Not Applicable

(1) Not applicable to this product.



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**

**EXAMINATION AND TEST (CONTINUED)**

**Model Type :- HY9320 FFP1/2 Foldable Masks**

CLAUSE	REQUIREMENT					ASSESSMENT	
7.16	<b>Breathing resistance (continued)</b>						
	Table E: Inhalation resistance @ 30 l/min						
	Sample No	Pre-test condition	Continuous flow (l/min)	Maximum specified inhalation resistance (mbar)	Actual inhalation resistance (mbar)		
	1	AR	30	0.6	0.33		Pass
	2	AR	30	0.6	0.35		Pass
	3	AR	30	0.6	0.33		Pass
	4	TC	30	0.6	0.30		Pass
	5	TC	30	0.6	0.33		Pass
	6	TC	30	0.6	0.32		Pass
	7	SW	30	0.6	0.38		Pass
	8	SW	30	0.6	0.33		Pass
	9	SW	30	0.6	0.34		Pass
	Table F: Inhalation resistance @ 95 l/min						
	Sample No	Pre-test condition	Continuous flow (l/min)	Maximum specified inhalation resistance (mbar)	Actual inhalation resistance (mbar)		
	1	AR	95	2.1	0.99		Pass
	2	AR	95	2.1	1.04		Pass
	3	AR	95	2.1	0.99		Pass
	4	TC	95	2.1	0.91		Pass
	5	TC	95	2.1	0.98		Pass
	6	TC	95	2.1	0.99		Pass
	7	SW	95	2.1	1.10		Pass
	8	SW	95	2.1	0.97		Pass
	9	SW	95	2.1	1.04		Pass

AR: As Received  
SW: Simulated Wear

TC: Temperature Conditioned  
FT: Flow tested at 300 l/min for 30 seconds



**BSI PRODUCT SERVICES**  
**BS EN 149:2001**

**EXAMINATION AND TEST (CONTINUED)**

**Model Type :- HY9320 FFP1/2 Foldable Masks**

CLAUSE	REQUIREMENT					ASSESSMENT
7.16	<b>Breathing resistance (continued)</b>					
	Table G: Exhalation resistance @ 160 l/min measured in five orientations - worst case recorded.					
	Sample No	Pre-test condition	Continuous flow (l/min)	Maximum specified exhalation resistance (mbar)	Actual exhalation resistance (mbar)	
	1	AR	160	3.0	1.53	
	2	AR	160	3.0	1.58	
	3	AR	160	3.0	1.52	
	4	TC	160	3.0	1.50	
	5	TC	160	3.0	1.63	
	6	TC	160	3.0	1.59	
	7	SW	160	3.0	1.75	
	8	SW	160	3.0	1.64	
	9	SW	160	3.0	1.71	

AR: As Received  
 SW: Simulated Wear

TC: Temperature Conditioned  
 FT: Flow tested at 300 l/min for 30 seconds